



TYPICAL MANHOLE VENT

NOTES:

1. VENT OPENING SHALL BE MIN. 4'-0" ABOVE FINISHED GRADE OR MIN. 1' ABOVE 100 YEAR FLOODPLAIN ELEVATION.
2. PRIME AND PAINT EXPOSED DIP USING TWO COATS OF POLYURETHANE. COLOR TO BE SELECTED BY PROJECT MANAGER FROM MANUFACTURER'S STANDARD COLORS.

REVISIONS

MOWAC WASTE WATER STANDARDS

MANHOLE VENT
DETAIL

MISSOURI AMERICAN WATER
ST. LOUIS, MO. 63141

MISSOURI AMERICAN WATER ENGINEERING
727 CRAIG ROAD
ST. LOUIS, MO. 63141



DRAWN BY
PROJECT ENG'R
APPROVED

DATE ##-##-2015
PROJECT IP

USE DIMENSIONS ONLY
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

MOAWC-WW-15