



## SANITARY FORCE MAIN CLEANOUT DETAIL

### NOTES:

1. VALVES, VALVE BOXES AND VALVE EXTENSIONS SHALL MEET THE SAME REQUIREMENTS AS SHOWN IN THE STANDARD WATER DETAILS.
2. VALVE MARKER POSTS SHALL MEET THE SAME REQUIREMENTS AS SHOWN IN THE WATER DETAILS AND BE PAINTED AS SPECIFIED IN THE STANDARD CONSTRUCTION NOTES.
3. ALL DIP AND FITTING SHALL BE PROTECTOR 401 EPOXY COATED. ALL PIPE AND FITTINGS SHALL BE RESTRAINED JOINT.

### REVISIONS

### MOWAC WASTE WATER STANDARDS SANITARY FORCE MAIN CLEANOUT DETAIL

MISSOURI AMERICAN WATER  
ST. LOUIS, MO. 63141

MISSOURI AMERICAN WATER ENGINEERING  
727 CRAIG ROAD  
ST. LOUIS, MO. 63141



DRAWN BY  
PROJECT ENG'R  
APPROVED

DATE ##-##-2015  
PROJECT IP

USE DIMENSIONS ONLY  
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY  
FOR CONSTRUCTION PURPOSES

MOAWC-WW-19